

TAMILNADU FIRE AND RESCUE SERVICE

SCHOOL NO OBJECTION CERTIFICATE

RC NO: 693/V/SPR/2022

DATED: 02/08/2022


Certificated that the M/s.TIAANO VIDYASHRM, at No. 250, Pushpagiri, Sethupattu Village, Manimangalam, Sriperumbudur Taluk, Kanchipuram District. comprised of Ground Floor and 1 upper floor occupied by M/s.TIAANO VIDYASHRM, have Fire Service Rules, and verified by the officers concerned of Fire Service on 02/08/2022 in the presence of Principal, M/s. TIAANO VIDYASHRM, No. 250, Pushpagiri, Sethupattu Village, Manimangalam and that the building/premises is for occupancy class School Premises with effect from 02/08/2022 for a period of 01/08/2023 Years in accordance with rule and subject to compliance of the conditions.

CONDITIONS

1. This License is valid for One year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure-better fire and life safety measures the Following additional measures are insisted.
6. a). Building occupancy capacity should not be more than 4 people per Sq. meter as per The National Building Code-2016.
b). The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of children.
c). As per Para 6.3 of the BIS Standards IS 14435:1997 as the Classrooms have only One entrance, the capacity of the class room shall have to be limited to 45 students.

TO:

M/s.Tiaano Vidyashrm,
No. 250, Pushpagiri, Sethupattu Village,
Manimangalam,Sriperumbudur Taluk,
Kancheepuram District.



Station Officer,
Fire and Rescue Service,
Sriperumbudur.

Copy to : District officer, Kanchipuram District.

Tiaano Vidyashrm


Principal

For TIAANO VIDYASHRM


Secretary